

# “VENTILATION SYSTEM OPTIMIZATION FOR DEEPENING OF HIGHLY MECHANIZED UNDERGROUND HARD ROCK MINES”

Daniel Naupari  
Mine & Flows

September 26th, 2023



# PRESENTATION OUTLINE


---

1. Mining in Peru and the Andes
2. Modern Mine Ventilation System Design
3. Prefeasibility Base Model
4. Case Study Conditions
5. Feasibility Study: Opportunities for Improvement
6. Results and LOM Simulation
7. Conclusions
8. Future Work




# Mining in Peru


## MINING METHOD



## DISTRIBUTION OF UNDERGROUND MINES BY ELEVATION



# Mining in the Andes




# Modern Mine Ventilation System Design

- *Sequenced Modelling*




- Construction



## BUILD-UP THE MODEL

- Create the airways based on the mine maps
- Adjust the dimensions for each excavation
- Define the openings and the close ends




## Modern Mine Ventilation System Design

- *Sequenced Modelling*



• Construction




• Calibration



• Simulation

### CALIBRATION

- Adjust environmental conditions
- Add & Set up fans to operational parameters
  - Adjust resistances and friction factors




## Modern Mine Ventilation System Design

- *Sequenced Modelling*



- Construction



- Calibration



- Simulation

### SIMULATION STAGE FOR LONG-TERM PLANNING

- Model able to simulate feasible scenarios
- Ventilation design aligned with production forecast
- Accurate simulation of power consumption


# Prefeasibility Study

---

Base Case








## MINE CONDITIONS:



- Elevation : 4,799 MASL
- Extension : 4,667 m
- Current Depth : 733 m
- Projected Depth : 1,256 m
- Mining Method : Sublevel Stoping
- Hauling Equipment : Trucks

## INTAKE CIRCUIT:


- Zoned (South).
- Vertical distance of 1,340 m
- Two parallel circuits directed to the same zone.
- Defined main levels.
- Effective fresh-air circuit to the bottom level.
- Air density of 0.64 kg/m<sup>3</sup>.




# Prefeasibility



- Air density of 0.64 kg/m<sup>3</sup>.






## EXHAUST CIRCUIT:

- Zoned (North).
- Horizontal distance of 3,432 m.
- Exhaust through mid-upper zone towards portal (BM).
- Air density of 0.64 kg/m<sup>3</sup>.




# Prefeasibility Base Model



Environment	
Air Density Compressible Flow	0.64 kg/m <sup>3</sup>
Air Density Incompressible Flow	0.64 kg/m <sup>3</sup>
Surface Temperature Adjust	Si
Current Year	2021.515
Rock Specific Heat	790.0 J/kgC
Rock Thermal Conductivity	2.00 W/mC
Rock Density	2.700 kg/m <sup>3</sup>
Rock Thermal Diffusivity	0.938 m <sup>2</sup> /s 10-6
Airway Age	5.000 years
Surface Datum of MineGrid	4,866.4 m
Rock Wetness Fraction	0.15
Geothermal Gradient	2.5 C/100m
Surface Datum Pressure Barometric	56.221 kPa
Surface Atmospheric Lapse Rate	6.4 C/1000m
Surface Datum Relative Humidity	39.7 R
Surface Datum Elevation Above Sea Level	4,700.0 m
Surface Datum Rock Temperature	20.0 C
Surface Datum Temperature Wet Bulb	20.0 C
Surface Datum Temperature Dry Bulb	30.0 C



# Prefeasibility Base Model



Friction Factors (kg/m <sup>3</sup> )	
<b>Custom</b>	
<b>Auto</b>	
*Raises	<b>0.013</b>
*Airways	<b>0.01</b>
*Ramps	<b>0.014</b>
*RaiseBored Airway	<b>0.005</b>
Smooth Blasted	<b>0.0085</b>
Average Blasted	<b>0.012</b>
Rough Blasted	<b>0.015</b>
Very Rough Blasted	<b>0.02</b>
Concrete Lined Airway	<b>0.0033</b>
Concrete Shaft Sets	<b>0.0417</b>
Timbered Airway	<b>0.0333</b>
Flexible Duct	<b>0.0029</b>

# Prefeasibility Base Model

### AIRFLOW REQUIREMENT BY EQUIPMENT TYPE




$$\sum [(Diesel\ Equipment + Workers + Temperature\ Control + Wood\ Consumption) + Leaks\ (15\%)]$$

D.S.N°024-2016 and modifications from D.S.N°023-2017:

§ ART. 252 (d) "The airflow requirements in the mine must be the sum of the airflow required by workers, the airflow to maintain appropriate temperature conditions in the working area and the airflow for the operation of diesel equipment. If there is no diesel equipment in the mine, it must be considered instead the airflow required to ensure gas dilution from the blasting, in accordance with the guidelines from Annex 38".

# Prefeasibility Base Model




Prefeasibility Study - CAPEX	
Component / Activity	Escalated value
<b>Ventilation Infrastructure</b>	
Ventilation Circuit - TRONCAL TR 03	\$ 6,097,892
Ventilation Circuit - TRONCAL TR 04	\$ 6,258,108
Secondary Ventilation System	\$ 2,866,347
<b>Power Distribution System</b>	
Electric Substation + Distribution No. 01 (TR 03 + TR 04)	\$ 7,852,259
Electric Substation + Distribution No. 02 (Secondary System)	\$ 225,374
<b>CAPEX PFS</b>	<b>\$ 23,299,979</b>

Prefeasibility Study - OPEX	
Component / Activity	Escalated value
Power consumption	\$ 22,320,716
<b>NPV OPEX</b>	<b>\$ 11,201,248</b>

**IRR: annual 12 %**



# Case Study Conditions



Main Portal Elevation at 4,800 MASL



Air Density: 0.73 kg/m<sup>3</sup>



Barometric Pressure: ~58,270 Pa



Dry Temperature: 2.36 - 11.20 °C



Relative Humidity: 43 - 67 %



Power Cost: 0.072 US\$/Kw-hr


# Feasibility Study

---

In-Depth Analysis




# Ventsim Model Calibration




### AVERAGE VALUES

	Dry Temperature (°C)	Relative Humidity (%)	Barometric Pressure (Pa)
AVG Day	11.20	42.85	58,282.91
AVG Night	2.60	39.7	58,260.32
Prefeasibility	30.0	39.7	56,221.00





# Ventsim Model Calibration


Environment	PFS	FS
Air Density Compressible Flow	0.64 kg/m <sup>3</sup>	0.73 kg/m <sup>3</sup>
Air Density Incompressible Flow	0.64 kg/m <sup>3</sup>	0.64 kg/m <sup>3</sup>
Surface Temperature Adjust	Si	Si
Current Year	2021.515	2021.515
Rock Specific Heat	790.0 J/kgC	790.0 J/kgC
Rock Thermal Conductivity	2.00 W/mC	2.00 W/mC
Rock Density	2.700 kg/m <sup>3</sup>	2.700 kg/m <sup>3</sup>
Rock Thermal Diffusivity	0.938 m <sup>2</sup> /s 10-6	0.938 m <sup>2</sup> /s 10-6
Airway Age	5.000 years	5.000 years
Surface Datum of MineGrid	4,866.4 m	4,866.4 m
Rock Wetness Fraction	0.15	0.15
Geothermal Gradient	2.5 C/1000m	2.5 C/1000m
Surface Datum Pressure Barometric	56.221 kPa	56.221 kPa
Surface Atmospheric Lapse Rate	6.4 C/1000m	6.4 C/1000m
Surface Datum Relative Humidity	39.7 R	39.7 R
Surface Datum Elevation Above Sea Level	4,700.0 m	4,700.0 m
Surface Datum Rock Temperature	20.0 C	20.0 C
Surface Datum Temperature Wet Bulb	20.0 C	-0.3 C
Surface Datum Temperature Dry Bulb	30.0 C	2.6 C



**FORMER FRICTION FACTORS CONFIGURATION**



**FINAL FRICTION FACTORS CONFIGURATION**



## FEASIBILITY MODEL - AIRFLOW REQUIREMENTS



	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035
Total Pre-Feasibility (KCFM)	302	705	1,028	1,235	1,255	1,362	1,321	1,281	1,364	1,381	1,276	1,377	1,194	1,113	1,050
Total Feasibility (KCFM)	47	682	1,091	1,075	1,251	1,276	1,215	1,121	1,060	1,141	1,130	1,138	1,039	1,141	850

# Re-evaluation of the ventilation infrastructure

---

TR C – TR D



# Opportunities for Improvement

## • REUSE

- Use of existing infrastructure for the new design of the ventilation circuits.

## • RECONFIGURATION

- Reconfiguration of TR\_C and TR\_D circuits.
- Decrease of operating costs based on the optimization of power consumption.

## • GAP

- Analysis of variations between original conditions and new design.
- Opportunity to define new evacuation routes toward the portal.




# Opportunities for Improvement




## REDISTRIBUTION:


- Zoned (Lower levels).
- Vertical distance of 1,340 m.
- Single intake circuit towards the lower levels.
- Effective fresh-air circuit to the bottom level.
- Air density of 0.73 kg/m<sup>3</sup>.

$$P \text{ \& } Q^3$$



# Opportunities for Improvement





## FRESH-AIR INTAKE

- Zoned (Mid-Lower levels).
- Horizontal distance of 3,432 m.
- Intake circuit from portal (BM) towards mid-lower levels.
- Air density of 0.73 kg/m<sup>3</sup>.



# Main Fans' Operating Points

---


TR B – TR C – TR D





# Fan curve – Prefeasibility (2032)




- Operating Point : 100 %
- Effective Airflow : 339.3 KCFM
- Total Pressure : 10.081 w.g.inch
- Efficiency : 75.2 %
- Power : 1,131 HP





# Fan curve – Prefeasibility (2032)




- Operating Point : 100 %
- Effective Airflow : 339.3 KCFM
- Total Pressure : 10.088 w.g.inch
- Efficiency : 75.2 %
- Power : 1,131 HP





# Fan curve – Feasibility (2032)




- Operating Point : 97 %
- Effective Airflow : 241.5 KCFM
- Total Pressure : 11.859 w.g.inch
- Efficiency : 77.9 %
- Power : 617.1 HP



# Fan curve – Feasibility (2026)




- Operating Point : 97 %
- Effective Airflow : 233.2 KCFM
- Total Pressure : 12.164 w.g.inch
- Efficiency : 75.4 %
- Power : 624 HP







# Fan curve – Feasibility (2026)



- Operating Point : 97 %
- Effective Airflow : 188.4 KCFM
- Total Pressure : 14.183 w.g.inch
- Efficiency : 82.5 %
- Power : 536.6 HP



# Results



## Prefeasibility Study - CAPEX

Component / Activity	Escalated value
Ventilation Infrastructure	
Ventilation Circuit - TRONCAL TR 03	\$ 6,097,892
Ventilation Circuit - TRONCAL TR 04	\$ 6,258,108
Secondary ventilation System	\$ 2,866,347
Power Distribution System	
Electric Substation + Distribution No. 01 (TR 03 + TR 04)	\$ 7,852,259
Electric Substation + Distribution No. 02 (Secondary System)	\$ 225,374

**CAPEX PFS \$ 23,299,979**

## Prefeasibility Study - OPEX

Component / Activity	Escalated value
Power Consumption	\$ 22,320,716

**NPV OPEX \$ 11,201,248**

## Feasibility Study - CAPEX

Component/ Activity	Escalated Value
Ventilation Infrastructure	
Ventilation Circuit-TRONCAL TR 02	\$ 1,699,152
Ventilation Circuit-TRONCAL TR 03	\$ 1,791,015
Ventilation Circuit-TRONCAL TR 04	\$ 1,783,941
Power Distribution System	
Electric Substation + Distribution N° 01 (TR 03 + TR 04)	\$ 7,852,259

**CAPEX FS \$ 13,126,367**

## Feasibility Study - OPEX

Component / Activity	Escalated value
Power Consumption	\$ 12,928,244

**NPV OPEX \$ 6,554,564**

**TIR: 12 % annual**

**CAPEX Savings : \$ 10,173,612**  
**OPEX Savings : \$ 4,646,683**  
**TOTAL Savings : \$ 14,820,295**


# SIMULATION STAGE

---

Base Model + Calibration +  
Operational Plans



# Results – Simulation Stage




YEAR	ID
2023	

COVERAGE PER YEAR



# Results – Simulation Stage




YEAR	ID
2023	
2024	

COVERAGE PER YEAR




# Results – Simulation Stage




YEAR	ID
2023	
2024	
2025	

COVERAGE PER YEAR




# Results – Simulation Stage




YEAR	ID
2023	<span style="background-color: magenta; width: 20px; height: 15px; display: inline-block;"></span>
2024	<span style="background-color: orange; width: 20px; height: 15px; display: inline-block;"></span>
2025	<span style="background-color: green; width: 20px; height: 15px; display: inline-block;"></span>
2026	<span style="background-color: red; width: 20px; height: 15px; display: inline-block;"></span>

COVERAGE PER YEAR




# Results – Simulation Stage




YEAR	ID
2023	<span style="background-color: magenta; border: 1px solid black; display: inline-block; width: 20px; height: 15px;"></span>
2024	<span style="background-color: orange; border: 1px solid black; display: inline-block; width: 20px; height: 15px;"></span>
2025	<span style="background-color: green; border: 1px solid black; display: inline-block; width: 20px; height: 15px;"></span>
2026	<span style="background-color: red; border: 1px solid black; display: inline-block; width: 20px; height: 15px;"></span>
2027	<span style="background-color: blue; border: 1px solid black; display: inline-block; width: 20px; height: 15px;"></span>

COVERAGE PER YEAR






# Results – Simulation Stage




YEAR	ID
2023	Magenta
2024	Orange
2025	Green
2026	Red
2027	Blue
2028	Olive

COVERAGE PER YEAR




# Results – Simulation Stage




YEAR	ID
2023	<span style="background-color: magenta; border: 1px solid black; display: inline-block; width: 20px; height: 15px;"></span>
2024	<span style="background-color: orange; border: 1px solid black; display: inline-block; width: 20px; height: 15px;"></span>
2025	<span style="background-color: green; border: 1px solid black; display: inline-block; width: 20px; height: 15px;"></span>
2026	<span style="background-color: red; border: 1px solid black; display: inline-block; width: 20px; height: 15px;"></span>
2027	<span style="background-color: blue; border: 1px solid black; display: inline-block; width: 20px; height: 15px;"></span>
2028	<span style="background-color: olive; border: 1px solid black; display: inline-block; width: 20px; height: 15px;"></span>
2029	<span style="background-color: yellow; border: 1px solid black; display: inline-block; width: 20px; height: 15px;"></span>

COVERAGE PER YEAR




# Results – Simulation Stage




YEAR	ID
2023	
2024	
2025	
2026	
2027	
2028	
2029	
20230	

COVERAGE PER YEAR




# Results – Simulation Stage




YEAR	ID
2023	
2024	
2025	
2026	
2027	
2028	
2029	
2030	
2031	

COVERAGE PER YEAR




# Results – Simulation Stage




YEAR	ID
2023	[Magenta]
2024	[Orange]
2025	[Green]
2026	[Red]
2027	[Blue]
2028	[Olive]
2029	[Yellow]
2030	[Purple]
2031	[Brown]
2032	[Teal]

COVERAGE PER YEAR




■ Airflow Requirements CFM   
 ■ Airflow Intake   
 — Coverage

# Results – Simulation Stage




YEAR	ID
2023	[Magenta]
2024	[Orange]
2025	[Green]
2026	[Red]
2027	[Blue]
2028	[Olive]
2029	[Yellow]
2030	[Light Blue]
2031	[Brown]
2032	[Teal]
2033	[Purple]

COVERAGE PER YEAR




# Results – Simulation Stage




YEAR	ID
2023	[Magenta]
2024	[Orange]
2025	[Green]
2026	[Red]
2027	[Blue]
2028	[Olive]
2029	[Yellow]
2030	[Purple]
2031	[Brown]
2032	[Teal]
2033	[Light Purple]
2034	[Dark Green]

COVERAGE PER YEAR




■ Airflow Requirements CFM    
 ■ Airflow Intake    
 — Coverage

# Results – Simulation Stage



YEAR	ID
2023	
2024	
2025	
2026	
2027	
2028	
2029	
2030	
2031	
2032	
2033	
2034	
2035	

COVERAGE PER YEAR



■ Airflow Requirements CFM   
 ■ Airflow Intake   
 — Coverage



- The process of model construction and parameters calibration is fundamental to obtain a reliable model, adjusted to reality and accurate enough to be able to plan and simulate multiple scenarios, and find opportunities of improvement. Ventsim is a software that makes this process simple, practical and highly illustrative.
- After the assessment of multiple scenarios, the results converged in a trade-off analysis between the ventilation infrastructure (CAPEX) and the fan selection (power consumption – OPEX), resulting in an important reduction of overall costs with respect to the initial estimations at the Prefeasibility Stage, with savings up to \$10.1 million in CAPEX and \$4.6 million in the net present value of the OPEX.
- Having the possibility to schedule the expansion of the mine ventilation system by years was a key part of the analysis in the estimation of the maximum airflow requirement over LOM, directly impacting in the decision of the economic diameter, and adjusting the fan operating point to what will be required, reducing a considerable amount of power consumption in benefit of the mine economics.

# Future Work

The operator has been evaluating the need for a fire, heat and contaminants simulation process for the short-, medium- and long-term. However, given the uncertainty of certain operational parameters unrelated to the ventilation process, it may require some time before the decision is made and the next ventilation assessment takes place.



# Questions?

[contacto@mineflows.com](mailto:contacto@mineflows.com)

Ventilation, safety and productivity for  
your operation.

